

# *e-Fire*™

## Inspection Report

**Prepared For:**



## **Sample Building**

**1234 Guardian Lane, Atlanta, Georgia**

**Inspection Date:**

**Wednesday, August 24, 2005**

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126

# e-Fire™ Inspection Results

Report Date: 8/30/2005

Page 1 of 8

Device Location	Device Type	Inspection Task	Result	Insp.Date	Unit #
<b>Sample Building</b>					
<b>01st Floor</b>					
Control Panel	Battery	Current/Voltage Test	Disc. #04	8/27/2005	11244
Elevator Room	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11123
Lobby	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11124
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Disc. #01	8/27/2005	11125
Pump Room	Tamper Switch	TestedManually Test	Pass	8/27/2005	11126
Pump Room	Tamper Switch	TestedManually Test	Pass	8/27/2005	11127
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/27/2005	11247
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11122
Control Panel	Battery	Current/Voltage Test	Disc. #05	8/27/2005	11245
Pump Room	Flow Switch	Electrically Tested	Pass	8/27/2005	11130
Control Panel	Battery	Current/Voltage Test	Pass	8/27/2005	11243
Control Panel	Battery	Current/Voltage Test	Pass	8/27/2005	11242
Pump Room	Tamper Switch	Manually Tested	Disc. #02	8/27/2005	11128
Pump Room	Flow Switch	Electrically Tested	Pass	8/27/2005	11129
Lobby	Pull Station	Manually Tested	Pass	8/27/2005	11131
West Exit	Pull Station	Manually Tested	Pass	8/27/2005	11133
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/27/2005	11246
Fire Control Room	Control Panel	Manually Tested	Pass	8/27/2005	11120
East Exit	Pull Station	Manually Tested	Pass	8/27/2005	11132
South Exit	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11121
<b>02nd Floor</b>					
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11137
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/27/2005	11248
East Stairwell	Tamper Switch	Manually Tested	Pass	8/27/2005	11291
East Stairwell	Flow Switch	Electrically Tested	Pass	8/27/2005	11290
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11134
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/27/2005	11249
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11136

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Inspection Results

Report Date: 8/30/2005

Page 2 of 8

Device Location	Device Type	Inspection Task	Result	Insp.Date	Unit #
<b>Sample Building</b>					
<b>02nd Floor</b>					
West Stairwell	Pull Station	Manually Tested	Pass	8/27/2005	11139
East Stairwell	Pull Station	Manually Tested	Pass	8/27/2005	11138
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11135
<b>03rd Floor</b>					
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11140
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11142
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Disc. #03	8/27/2005	11143
East Stairwell	Pull Station	Manually Tested	Pass	8/27/2005	11144
East Stairwell	Flow Switch	Electrically Tested	Pass	8/27/2005	11292
East Stairwell	Tamper Switch	Manually Tested	Pass	8/27/2005	11293
West Stairwell	Pull Station	Manually Tested	Pass	8/27/2005	11145
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11141
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/27/2005	11250
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/27/2005	11251
<b>04th Floor</b>					
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11149
East Stairwell	Pull Station	Manually Tested	Pass	8/27/2005	11150
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11148
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11147
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/27/2005	11146
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/27/2005	11253
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/27/2005	11252
West Stairwell	Pull Station	Manually Tested	Pass	8/27/2005	11151
East Stairwell	Tamper Switch	Manually Tested	Pass	8/26/2005	11295
East Stairwell	Flow Switch	Electrically Tested	Pass	8/27/2005	11294
<b>05th Floor</b>					
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11153
West Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11157

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Inspection Results

Report Date: 8/30/2005

Page 3 of 8

Device Location	Device Type	Inspection Task	Result	Insp.Date	Unit #
<b>Sample Building</b>					
<b>05th Floor</b>					
East Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11156
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11154
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11152
East Stairwell	Tamper Switch	Manually Tested	Pass	8/26/2005	11297
East Stairwell	Flow Switch	Electrically Tested	Pass	8/26/2005	11296
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11155
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11254
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11255
<b>06th Floor</b>					
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11159
West Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11163
East Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11162
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11160
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11158
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11256
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11257
East Stairwell	Flow Switch	Electrically Tested	Pass	8/26/2005	11298
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11161
East Stairwell	Tamper Switch	Manually Tested	Pass	8/26/2005	11299
<b>07th Floor</b>					
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11164
West Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11169
East Stairwell	Pull Station	Manually Tested	Disc. #06	8/26/2005	11168
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11167
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11165
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11258
East Stairwell	Flow Switch	Electrically Tested	Pass	8/26/2005	11300
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11166

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Inspection Results

Report Date: 8/30/2005

Page 4 of 8

Device Location	Device Type	Inspection Task	Result	Insp.Date	Unit #
<b>Sample Building</b>					
<b>07th Floor</b>					
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11259
East Stairwell	Tamper Switch	Manually Tested	Pass	8/26/2005	11301
<b>08th Floor</b>					
West Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11175
East Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11174
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11173
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11172
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/30/2005	11171
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11170
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11260
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11261
East Stairwell	Flow Switch	Electrically Tested	Pass	8/26/2005	11302
East Stairwell	Tamper Switch	Manually Tested	Pass	8/26/2005	11303
<b>09th Floor</b>					
East Stairwell	Flow Switch	Electrically Tested	Pass	8/26/2005	11304
East Stairwell	Tamper Switch	Manually Tested	Pass	8/26/2005	11305
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11176
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11177
West Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11181
East Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11180
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11263
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11262
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11179
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11178
<b>10th Floor</b>					
West Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11187
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11265
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11264

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Inspection Results

Report Date: 8/30/2005

Page 5 of 8

Device Location	Device Type	Inspection Task	Result	Insp.Date	Unit #
<b>Sample Building</b>					
<b>10th Floor</b>					
East Stairwell	Flow Switch	Electrically Tested	Pass	8/26/2005	11306
East Stairwell	Tamper Switch	Manually Tested	Pass	8/26/2005	11307
East Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11186
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11185
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11184
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11183
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11182
<b>11th Floor</b>					
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11267
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11191
East Stairwell	Flow Switch	Electrically Tested	Pass	8/26/2005	11308
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11266
East Stairwell	Tamper Switch	Manually Tested	Pass	8/26/2005	11309
East Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11192
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11190
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11189
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11188
West Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11193
<b>12th Floor</b>					
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11268
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11197
East Stairwell	Flow Switch	Electrically Tested	Pass	8/26/2005	11310
East Stairwell	Tamper Switch	Manually Tested	Pass	8/26/2005	11311
East Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11198
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11196
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11195
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/26/2005	11194
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/26/2005	11269

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Inspection Results

Report Date: 8/30/2005

Page 6 of 8

Device Location	Device Type	Inspection Task	Result	Insp.Date	Unit #
<b>Sample Building</b>					
<b>12th Floor</b>					
West Stairwell	Pull Station	Manually Tested	Pass	8/26/2005	11199
<b>14th Floor</b>					
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11270
East Stairwell	Flow Switch	Electrically Tested	Pass	8/25/2005	11312
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11202
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11271
West Stairwell	Pull Station	Manually Tested	Pass	8/25/2005	11205
East Stairwell	Tamper Switch	Manually Tested	Pass	8/25/2005	11313
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11203
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11201
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11200
East Stairwell	Pull Station	Manually Tested	Pass	8/25/2005	11204
<b>15th Floor</b>					
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11273
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11272
East Stairwell	Tamper Switch	Manually Tested	Pass	8/25/2005	11315
East Stairwell	Pull Station	Manually Tested	Pass	8/25/2005	11210
West Stairwell	Pull Station	Manually Tested	Pass	8/25/2005	11211
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11206
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11207
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11208
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11209
East Stairwell	Flow Switch	Electrically Tested	Pass	8/25/2005	11314
<b>16th Floor</b>					
East Stairwell	Flow Switch	Electrically Tested	Pass	8/25/2005	11316
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11212
West Stairwell	Pull Station	Manually Tested	Pass	8/25/2005	11217
East Stairwell	Tamper Switch	Manually Tested	Pass	8/25/2005	11317

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Inspection Results

Report Date: 8/30/2005

Page 7 of 8

Device Location	Device Type	Inspection Task	Result	Insp.Date	Unit #
<b>Sample Building</b>					
<b>16th Floor</b>					
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11213
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11214
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11215
East Stairwell	Pull Station	Manually Tested	Pass	8/25/2005	11216
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11275
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11274
<b>17th Floor</b>					
East Stairwell	Flow Switch	Electrically Tested	Pass	8/25/2005	11318
East Stairwell	Tamper Switch	Manually Tested	Pass	8/25/2005	11319
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11276
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11277
West Stairwell	Pull Station	Manually Tested	Pass	8/25/2005	11223
East Stairwell	Pull Station	Manually Tested	Pass	8/25/2005	11222
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11221
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11220
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11218
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11219
<b>18th Floor</b>					
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11278
Mechanical Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11224
Mechanical Room	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11279
East Stairwell	Flow Switch	Electrically Tested	Pass	8/25/2005	11320
East Stairwell	Tamper Switch	Manually Tested	Pass	8/25/2005	11321
West Stairwell	Pull Station	Manually Tested	Pass	8/25/2005	11229
East Stairwell	Pull Station	Manually Tested	Pass	8/25/2005	11228
Service Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11227
Electrical Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11225
Passenger Elevator Lobby	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11226

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126





# e-Fire™ Inspection Results

Report Date: 8/30/2005

Page 8 of 8

---

Device Location	Device Type	Inspection Task	Result	Insp.Date	Unit #
-----------------	-------------	-----------------	--------	-----------	--------

---

## Sample Building

### *PH Floor*

East Stairwell	Flow Switch	Electrically Tested	Pass	8/25/2005	11328
East Stairwell	Tamper Switch	Manually Tested	Pass	8/25/2005	11329
Elevator Room	Smoke Detector	Tested & Cleaned	Pass	8/25/2005	11330
East Stairwell	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11286
West Stairwell	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11287
Elevator Shaft #1	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11288
Elevator Shaft #2	Duct Detector	Tested & Cleaned	Pass	8/25/2005	11289

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

---

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Zone Detail

Report Date: 8/30/2005

Page 1 of 9

Floor	Device Location	Device Type	Unit #
<b>Sample Building</b>			
<b>Zone 1</b>			
01st Floor	South Exit	Smoke Detector	11121
01st Floor	Electrical Room	Smoke Detector	11122
01st Floor	Mechanical Room	Duct Detector	11246
01st Floor	Mechanical Room	Duct Detector	11247
<b>Zone 2</b>			
01st Floor	Elevator Room	Smoke Detector	11123
<b>Zone 3</b>			
01st Floor	Lobby	Smoke Detector	11124
01st Floor	Service Elevator Lobby	Smoke Detector	11125
<b>Zone 4</b>			
01st Floor	Pump Room	Tamper Switch	11127
01st Floor	Pump Room	Tamper Switch	11128
01st Floor	Pump Room	Tamper Switch	11126
<b>Zone 5</b>			
01st Floor	Pump Room	Flow Switch	11130
01st Floor	Pump Room	Flow Switch	11129
<b>Zone 6</b>			
01st Floor	Lobby	Pull Station	11131
01st Floor	East Exit	Pull Station	11132
01st Floor	West Exit	Pull Station	11133
<b>Zone 7</b>			
02nd Floor	Mechanical Room	Duct Detector	11249
02nd Floor	Mechanical Room	Duct Detector	11248
02nd Floor	Mechanical Room	Smoke Detector	11134
02nd Floor	Electrical Room	Smoke Detector	11135
<b>Zone 8</b>			
02nd Floor	Passenger Elevator Lobby	Smoke Detector	11136
02nd Floor	Service Elevator Lobby	Smoke Detector	11137
<b>Zone 9</b>			
02nd Floor	East Stairwell	Pull Station	11138
02nd Floor	West Stairwell	Pull Station	11139

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2006 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Zone Detail

Report Date: 8/30/2005

Page 2 of 9

Floor	Device Location	Device Type	Unit #
<b>Sample Building</b>			
<b>Zone 10</b>			
03rd Floor	Mechanical Room	Smoke Detector	11140
03rd Floor	Electrical Room	Smoke Detector	11141
03rd Floor	Mechanical Room	Duct Detector	11250
03rd Floor	Mechanical Room	Duct Detector	11251
<b>Zone 11</b>			
03rd Floor	Passenger Elevator Lobby	Smoke Detector	11142
03rd Floor	Service Elevator Lobby	Smoke Detector	11143
<b>Zone 12</b>			
03rd Floor	East Stairwell	Pull Station	11144
03rd Floor	West Stairwell	Pull Station	11145
<b>Zone 13</b>			
04th Floor	Mechanical Room	Duct Detector	11253
04th Floor	Mechanical Room	Duct Detector	11252
04th Floor	Electrical Room	Smoke Detector	11147
04th Floor	Mechanical Room	Smoke Detector	11146
<b>Zone 14</b>			
04th Floor	Passenger Elevator Lobby	Smoke Detector	11148
04th Floor	Service Elevator Lobby	Smoke Detector	11149
<b>Zone 15</b>			
04th Floor	East Stairwell	Pull Station	11150
04th Floor	West Stairwell	Pull Station	11151
<b>Zone 16</b>			
05th Floor	Mechanical Room	Duct Detector	11254
05th Floor	Mechanical Room	Duct Detector	11255
05th Floor	Electrical Room	Smoke Detector	11153
05th Floor	Mechanical Room	Smoke Detector	11152
<b>Zone 17</b>			
05th Floor	Service Elevator Lobby	Smoke Detector	11155
05th Floor	Passenger Elevator Lobby	Smoke Detector	11154
<b>Zone 18</b>			
05th Floor	West Stairwell	Pull Station	11157

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2006 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Zone Detail

Report Date: 8/30/2005

Page 3 of 9

Floor	Device Location	Device Type	Unit #
<b>Sample Building</b>			
<b>Zone 18</b>			
05th Floor	East Stairwell	Pull Station	11156
<b>Zone 19</b>			
06th Floor	Mechanical Room	Smoke Detector	11158
06th Floor	Electrical Room	Smoke Detector	11159
06th Floor	Mechanical Room	Duct Detector	11257
06th Floor	Mechanical Room	Duct Detector	11256
<b>Zone 20</b>			
06th Floor	Service Elevator Lobby	Smoke Detector	11161
06th Floor	Passenger Elevator Lobby	Smoke Detector	11160
<b>Zone 21</b>			
06th Floor	West Stairwell	Pull Station	11163
06th Floor	East Stairwell	Pull Station	11162
<b>Zone 22</b>			
07th Floor	Mechanical Room	Smoke Detector	11164
07th Floor	Electrical Room	Smoke Detector	11165
07th Floor	Mechanical Room	Duct Detector	11258
07th Floor	Mechanical Room	Duct Detector	11259
<b>Zone 23</b>			
07th Floor	Service Elevator Lobby	Smoke Detector	11167
07th Floor	Passenger Elevator Lobby	Smoke Detector	11166
<b>Zone 24</b>			
07th Floor	East Stairwell	Pull Station	11168
07th Floor	West Stairwell	Pull Station	11169
<b>Zone 25</b>			
08th Floor	Mechanical Room	Duct Detector	11260
08th Floor	Mechanical Room	Duct Detector	11261
08th Floor	Mechanical Room	Smoke Detector	11170
08th Floor	Electrical Room	Smoke Detector	11171
<b>Zone 26</b>			
08th Floor	Passenger Elevator Lobby	Smoke Detector	11172
08th Floor	Service Elevator Lobby	Smoke Detector	11173

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2006 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Zone Detail

Report Date: 8/30/2005

Page 4 of 9

Floor	Device Location	Device Type	Unit #
<b>Sample Building</b>			
<b>Zone 27</b>			
08th Floor	East Stairwell	Pull Station	11174
08th Floor	West Stairwell	Pull Station	11175
<b>Zone 28</b>			
09th Floor	Mechanical Room	Smoke Detector	11176
09th Floor	Electrical Room	Smoke Detector	11177
09th Floor	Mechanical Room	Duct Detector	11262
09th Floor	Mechanical Room	Duct Detector	11263
<b>Zone 29</b>			
09th Floor	Passenger Elevator Lobby	Smoke Detector	11178
09th Floor	Service Elevator Lobby	Smoke Detector	11179
<b>Zone 30</b>			
09th Floor	East Stairwell	Pull Station	11180
09th Floor	West Stairwell	Pull Station	11181
<b>Zone 31</b>			
10th Floor	Mechanical Room	Duct Detector	11264
10th Floor	Mechanical Room	Duct Detector	11265
10th Floor	Mechanical Room	Smoke Detector	11182
10th Floor	Electrical Room	Smoke Detector	11183
<b>Zone 32</b>			
10th Floor	Passenger Elevator Lobby	Smoke Detector	11184
10th Floor	Service Elevator Lobby	Smoke Detector	11185
<b>Zone 33</b>			
10th Floor	East Stairwell	Pull Station	11186
10th Floor	West Stairwell	Pull Station	11187
<b>Zone 34</b>			
11th Floor	Mechanical Room	Duct Detector	11267
11th Floor	Mechanical Room	Smoke Detector	11188
11th Floor	Electrical Room	Smoke Detector	11189
11th Floor	Mechanical Room	Duct Detector	11266
<b>Zone 35</b>			
11th Floor	Passenger Elevator Lobby	Smoke Detector	11190

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2006 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Zone Detail

Report Date: 8/30/2005

Page 5 of 9

Floor	Device Location	Device Type	Unit #
<b>Sample Building</b>			
<b>Zone 35</b>			
11th Floor	Service Elevator Lobby	Smoke Detector	11191
<b>Zone 36</b>			
11th Floor	East Stairwell	Pull Station	11192
11th Floor	West Stairwell	Pull Station	11193
<b>Zone 37</b>			
12th Floor	Mechanical Room	Smoke Detector	11194
12th Floor	Mechanical Room	Duct Detector	11268
12th Floor	Electrical Room	Smoke Detector	11195
12th Floor	Mechanical Room	Duct Detector	11269
<b>Zone 38</b>			
12th Floor	Passenger Elevator Lobby	Smoke Detector	11196
12th Floor	Service Elevator Lobby	Smoke Detector	11197
<b>Zone 39</b>			
12th Floor	East Stairwell	Pull Station	11198
12th Floor	West Stairwell	Pull Station	11199
<b>Zone 40</b>			
14th Floor	Mechanical Room	Duct Detector	11270
14th Floor	Mechanical Room	Duct Detector	11271
14th Floor	Mechanical Room	Smoke Detector	11200
14th Floor	Electrical Room	Smoke Detector	11201
<b>Zone 41</b>			
14th Floor	Passenger Elevator Lobby	Smoke Detector	11202
14th Floor	Service Elevator Lobby	Smoke Detector	11203
<b>Zone 42</b>			
14th Floor	East Stairwell	Pull Station	11204
14th Floor	West Stairwell	Pull Station	11205
<b>Zone 43</b>			
15th Floor	Mechanical Room	Smoke Detector	11206
15th Floor	Electrical Room	Smoke Detector	11207
15th Floor	Mechanical Room	Duct Detector	11272
15th Floor	Mechanical Room	Duct Detector	11273

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2006 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Zone Detail

Report Date: 8/30/2005

Page 6 of 9

Floor	Device Location	Device Type	Unit #
<b>Sample Building</b>			
<b>Zone 44</b>			
15th Floor	Service Elevator Lobby	Smoke Detector	11209
15th Floor	Passenger Elevator Lobby	Smoke Detector	11208
<b>Zone 45</b>			
15th Floor	West Stairwell	Pull Station	11211
15th Floor	East Stairwell	Pull Station	11210
<b>Zone 46</b>			
16th Floor	Mechanical Room	Duct Detector	11274
16th Floor	Electrical Room	Smoke Detector	11213
16th Floor	Mechanical Room	Duct Detector	11275
16th Floor	Mechanical Room	Smoke Detector	11212
<b>Zone 47</b>			
16th Floor	Passenger Elevator Lobby	Smoke Detector	11214
16th Floor	Service Elevator Lobby	Smoke Detector	11215
<b>Zone 48</b>			
16th Floor	East Stairwell	Pull Station	11216
16th Floor	West Stairwell	Pull Station	11217
<b>Zone 49</b>			
17th Floor	Mechanical Room	Duct Detector	11276
17th Floor	Electrical Room	Smoke Detector	11219
17th Floor	Mechanical Room	Duct Detector	11277
17th Floor	Mechanical Room	Smoke Detector	11218
<b>Zone 50</b>			
17th Floor	Service Elevator Lobby	Smoke Detector	11221
17th Floor	Passenger Elevator Lobby	Smoke Detector	11220
<b>Zone 51</b>			
17th Floor	West Stairwell	Pull Station	11223
17th Floor	East Stairwell	Pull Station	11222
<b>Zone 52</b>			
18th Floor	Mechanical Room	Duct Detector	11278
18th Floor	Mechanical Room	Duct Detector	11279
18th Floor	Electrical Room	Smoke Detector	11225

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2006 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Zone Detail

Report Date: 8/30/2005

Page 7 of 9

Floor	Device Location	Device Type	Unit #
<b>Sample Building</b>			
<b>Zone 52</b>			
18th Floor	Mechanical Room	Smoke Detector	11224
<b>Zone 53</b>			
18th Floor	Service Elevator Lobby	Smoke Detector	11227
18th Floor	Passenger Elevator Lobby	Smoke Detector	11226
<b>Zone 54</b>			
18th Floor	East Stairwell	Pull Station	11228
18th Floor	West Stairwell	Pull Station	11229
<b>Zone 55</b>			
PH Floor	East Stairwell	Duct Detector	11286
PH Floor	West Stairwell	Duct Detector	11287
PH Floor	Elevator Shaft #1	Duct Detector	11288
PH Floor	Elevator Shaft #2	Duct Detector	11289
<b>Zone 56</b>			
02nd Floor	East Stairwell	Flow Switch	11290
<b>Zone 57</b>			
02nd Floor	East Stairwell	Tamper Switch	11291
<b>Zone 58</b>			
03rd Floor	East Stairwell	Flow Switch	11292
<b>Zone 59</b>			
03rd Floor	East Stairwell	Tamper Switch	11293
<b>Zone 60</b>			
04th Floor	East Stairwell	Flow Switch	11294
<b>Zone 61</b>			
04th Floor	East Stairwell	Tamper Switch	11295
<b>Zone 62</b>			
05th Floor	East Stairwell	Flow Switch	11296
<b>Zone 63</b>			
05th Floor	East Stairwell	Tamper Switch	11297
<b>Zone 64</b>			
06th Floor	East Stairwell	Flow Switch	11298
<b>Zone 65</b>			
06th Floor	East Stairwell	Tamper Switch	11299

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2006 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126





# e-Fire™ Zone Detail

Report Date: 8/30/2005

Page 8 of 9

Floor	Device Location	Device Type	Unit #
<b>Sample Building</b>			
<b>Zone 66</b>			
07th Floor	East Stairwell	Flow Switch	11300
<b>Zone 67</b>			
07th Floor	East Stairwell	Tamper Switch	11301
<b>Zone 68</b>			
08th Floor	East Stairwell	Flow Switch	11302
<b>Zone 69</b>			
08th Floor	East Stairwell	Tamper Switch	11303
<b>Zone 70</b>			
09th Floor	East Stairwell	Flow Switch	11304
<b>Zone 71</b>			
09th Floor	East Stairwell	Tamper Switch	11305
<b>Zone 72</b>			
10th Floor	East Stairwell	Flow Switch	11306
<b>Zone 73</b>			
10th Floor	East Stairwell	Tamper Switch	11307
<b>Zone 74</b>			
11th Floor	East Stairwell	Flow Switch	11308
<b>Zone 75</b>			
11th Floor	East Stairwell	Tamper Switch	11309
<b>Zone 76</b>			
12th Floor	East Stairwell	Flow Switch	11310
<b>Zone 77</b>			
12th Floor	East Stairwell	Tamper Switch	11311
<b>Zone 78</b>			
14th Floor	East Stairwell	Flow Switch	11312
<b>Zone 79</b>			
14th Floor	East Stairwell	Tamper Switch	11313
<b>Zone 80</b>			
15th Floor	East Stairwell	Flow Switch	11314
<b>Zone 81</b>			
15th Floor	East Stairwell	Tamper Switch	11315
<b>Zone 82</b>			

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2006 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Zone Detail

Report Date: 8/30/2005

Page 9 of 9

Floor	Device Location	Device Type	Unit #
<b>Sample Building</b>			
<b>Zone 82</b>			
16th Floor	East Stairwell	Flow Switch	11316
<b>Zone 83</b>			
16th Floor	East Stairwell	Tamper Switch	11317
<b>Zone 84</b>			
17th Floor	East Stairwell	Flow Switch	11318
<b>Zone 85</b>			
17th Floor	East Stairwell	Tamper Switch	11319
<b>Zone 86</b>			
18th Floor	East Stairwell	Flow Switch	11320
<b>Zone 87</b>			
18th Floor	East Stairwell	Tamper Switch	11321
<b>Zone 88</b>			
PH Floor	East Stairwell	Flow Switch	11328
<b>Zone 89</b>			
PH Floor	East Stairwell	Tamper Switch	11329
<b>Zone 90</b>			
PH Floor	Elevator Room	Smoke Detector	11330

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2006 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Device Statistics

Report Date: 8/30/2005

Page 1 of 6

---

Manufacturer	Model #	Install Date	Device Location	Unit #
--------------	---------	--------------	-----------------	--------

---

## Sample Building

### *Battery*

Yuasa	NP12-12	6/1/2001	01st Fl Control Panel	11245
Yuasa	NP12-12	6/1/2001	01st Fl Control Panel	11244
Yuasa	NP17-12	7/1/2004	01st Fl Control Panel	11243
Yuasa	NP17-12	7/1/2004	01st Fl Control Panel	11242

### *Control Panel*

Simplex	4120	5/1/1991	01st Fl Fire Control Room	11120
---------	------	----------	---------------------------	-------

### *Duct Detector*

Fenwall	DD12	12/1/1990	01st Fl Mechanical Room	11247
Fenwall	DD12	12/1/1990	01st Fl Mechanical Room	11246
Fenwall	DD12	12/1/1990	02nd Fl Mechanical Room	11248
Fenwall	DD12	12/1/1990	02nd Fl Mechanical Room	11249
Fenwall	DD12	12/1/1990	03rd Fl Mechanical Room	11250
Fenwall	DD12	12/1/1990	03rd Fl Mechanical Room	11251
Fenwall	DD12	12/1/1990	04th Fl Mechanical Room	11253
Fenwall	DD12	12/1/1990	04th Fl Mechanical Room	11252
Fenwall	DD12	12/1/1990	05th Fl Mechanical Room	11254
Fenwall	DD12	12/1/1990	05th Fl Mechanical Room	11255
Fenwall	DD12	12/1/1990	06th Fl Mechanical Room	11256
Fenwall	DD12	12/1/1990	06th Fl Mechanical Room	11257
Fenwall	DD12	12/1/1990	07th Fl Mechanical Room	11258
Fenwall	DD12	12/1/1990	07th Fl Mechanical Room	11259
Fenwall	DD12	12/1/1990	08th Fl Mechanical Room	11261
Fenwall	DD12	12/1/1990	08th Fl Mechanical Room	11260
Fenwall	DD12	12/1/1990	09th Fl Mechanical Room	11263
Fenwall	DD12	12/1/1990	09th Fl Mechanical Room	11262
Fenwall	DD12	12/1/1990	10th Fl Mechanical Room	11265
Fenwall	DD12	12/1/1990	10th Fl Mechanical Room	11264
Fenwall	DD12	12/1/1990	11th Fl Mechanical Room	11266
Fenwall	DD12	12/1/1990	11th Fl Mechanical Room	11267
Fenwall	DD12	12/1/1990	12th Fl Mechanical Room	11268
Fenwall	DD12	12/1/1990	12th Fl Mechanical Room	11269
Fenwall	DD12	12/1/1990	14th Fl Mechanical Room	11271
Fenwall	DD12	12/1/1990	14th Fl Mechanical Room	11270
Fenwall	DD12	12/1/1990	15th Fl Mechanical Room	11272

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Device Statistics

Report Date: 8/30/2005

Page 2 of 6

<b>Manufacturer</b>	<b>Model #</b>	<b>Install Date</b>	<b>Device Location</b>	<b>Unit #</b>
---------------------	----------------	---------------------	------------------------	---------------

## Sample Building

### *Duct Detector*

Fenwall	DD12	12/1/1990	15th Fl Mechanical Room	11273
Fenwall	DD12	12/1/1990	16th Fl Mechanical Room	11274
Fenwall	DD12	12/1/1990	16th Fl Mechanical Room	11275
Fenwall	DD12	12/1/1990	17th Fl Mechanical Room	11276
Fenwall	DD12	12/1/1990	17th Fl Mechanical Room	11277
Fenwall	DD12	12/1/1990	18th Fl Mechanical Room	11278
Fenwall	DD12	12/1/1990	18th Fl Mechanical Room	11279
Fenwall	DD12	12/1/1990	PH Fl East Stairwell	11286
Fenwall	DD12	12/1/1990	PH Fl Elevator Shaft #1	11288
Fenwall	DD12	12/1/1990	PH Fl Elevator Shaft #2	11289
Fenwall	DD12	12/1/1990	PH Fl West Stairwell	11287

### *Flow Switch*

Potter	FS1	7/1/1991	01st Fl Pump Room	11129
Potter	FS1	7/1/1991	01st Fl Pump Room	11130
Potter	FS1	7/1/1991	02nd Fl East Stairwell	11290
Potter	FS1	7/1/1991	03rd Fl East Stairwell	11292
Potter	FS1	7/1/1991	04th Fl East Stairwell	11294
Potter	FS1	7/1/1991	05th Fl East Stairwell	11296
Potter	FS1	7/1/1991	06th Fl East Stairwell	11298
Potter	FS1	7/1/1991	07th Fl East Stairwell	11300
Potter	FS1	7/1/1991	08th Fl East Stairwell	11302
Potter	FS1	7/1/1991	09th Fl East Stairwell	11304
Potter	FS1	7/1/1991	10th Fl East Stairwell	11306
Potter	FS1	7/1/1991	11th Fl East Stairwell	11308
Potter	FS1	7/1/1991	12th Fl East Stairwell	11310
Potter	FS1	7/1/1991	14th Fl East Stairwell	11312
Potter	FS1	7/1/1991	15th Fl East Stairwell	11314
Potter	FS1	7/1/1991	16th Fl East Stairwell	11316
Potter	FS1	7/1/1991	17th Fl East Stairwell	11318
Potter	FS1	7/1/1991	18th Fl East Stairwell	11320
Potter	FS1	7/1/1991	PH Fl East Stairwell	11328

### *Pull Station*

Simplex	MS1	5/1/1991	01st Fl Lobby	11131
Simplex	MS1	5/1/1991	01st Fl West Exit	11133

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Device Statistics

Report Date: 8/30/2005

Page 3 of 6

---

Manufacturer	Model #	Install Date	Device Location	Unit #
--------------	---------	--------------	-----------------	--------

---

## Sample Building

### *Pull Station*

Simplex	MS1	5/1/1991	01st Fl East Exit	11132
Simplex	MS1	5/1/1991	02nd Fl East Stairwell	11138
Simplex	MS1	5/1/1991	02nd Fl West Stairwell	11139
Simplex	MS1	5/1/1991	03rd Fl East Stairwell	11144
Simplex	MS1	5/1/1991	03rd Fl West Stairwell	11145
Simplex	MS1	5/1/1991	04th Fl East Stairwell	11150
Simplex	MS1	5/1/1991	04th Fl West Stairwell	11151
Simplex	MS1	5/1/1991	05th Fl East Stairwell	11156
Simplex	MS1	5/1/1991	05th Fl West Stairwell	11157
Simplex	MS1	5/1/1991	06th Fl West Stairwell	11163
Simplex	MS1	5/1/1991	06th Fl East Stairwell	11162
Simplex	MS1	5/1/1991	07th Fl East Stairwell	11168
Simplex	MS1	5/1/1991	07th Fl West Stairwell	11169
Simplex	MS1	5/1/1991	08th Fl East Stairwell	11174
Simplex	MS1	5/1/1991	08th Fl West Stairwell	11175
Simplex	MS1	5/1/1991	09th Fl West Stairwell	11181
Simplex	MS1	5/1/1991	09th Fl East Stairwell	11180
Simplex	MS1	5/1/1991	10th Fl West Stairwell	11187
Simplex	MS1	5/1/1991	10th Fl East Stairwell	11186
Simplex	MS1	5/1/1991	11th Fl West Stairwell	11193
Simplex	MS1	5/1/1991	11th Fl East Stairwell	11192
Simplex	MS1	5/1/1991	12th Fl East Stairwell	11198
Simplex	MS1	5/1/1991	12th Fl West Stairwell	11199
Simplex	MS1	5/1/1991	14th Fl East Stairwell	11204
Simplex	MS1	5/1/1991	14th Fl West Stairwell	11205
Simplex	MS1	5/1/1991	15th Fl West Stairwell	11211
Simplex	MS1	5/1/1991	15th Fl East Stairwell	11210
Simplex	MS1	5/1/1991	16th Fl East Stairwell	11216
Simplex	MS1	5/1/1991	16th Fl West Stairwell	11217
Simplex	MS1	5/1/1991	17th Fl West Stairwell	11223
Simplex	MS1	5/1/1991	17th Fl East Stairwell	11222
Simplex	MS1	5/1/1991	18th Fl West Stairwell	11229
Simplex	MS1	5/1/1991	18th Fl East Stairwell	11228

### *Smoke Detector*

Simplex	2098-1234	1/1/1991	01st Fl South Exit	11121
---------	-----------	----------	--------------------	-------

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

---

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Device Statistics

Report Date: 8/30/2005

Page 4 of 6

---

Manufacturer	Model #	Install Date	Device Location	Unit #
--------------	---------	--------------	-----------------	--------

---

## Sample Building

### *Smoke Detector*

Simplex	2098-1234	1/1/1991	01st Fl Lobby	11124
Simplex	2098-1234	1/1/1991	01st Fl Electrical Room	11122
Simplex	2098-1234	1/1/1991	01st Fl Elevator Room	11123
Simplex	2098-1234	1/1/1991	01st Fl Service Elevator Lobby	11125
Simplex	2098-1234	1/1/1991	02nd Fl Electrical Room	11135
Simplex	2098-1234	1/1/1991	02nd Fl Passenger Elevator Lobby	11136
Simplex	2098-1234	1/1/1991	02nd Fl Service Elevator Lobby	11137
Simplex	2098-1234	1/1/1991	02nd Fl Mechanical Room	11134
Simplex	2098-1234	1/1/1991	03rd Fl Mechanical Room	11140
Simplex	2098-1234	1/1/1991	03rd Fl Service Elevator Lobby	11143
Simplex	2098-1234	1/1/1991	03rd Fl Electrical Room	11141
Simplex	2098-1234	1/1/1991	03rd Fl Passenger Elevator Lobby	11142
Simplex	2098-1234	1/1/1991	04th Fl Electrical Room	11147
Simplex	2098-1234	1/1/1991	04th Fl Passenger Elevator Lobby	11148
Simplex	2098-1234	1/1/1991	04th Fl Service Elevator Lobby	11149
Simplex	2098-1234	5/1/1991	04th Fl Mechanical Room	11146
Simplex	2098-1234	1/1/1991	05th Fl Electrical Room	11153
Simplex	2098-1234	1/1/1991	05th Fl Service Elevator Lobby	11155
Simplex	2098-1234	1/1/1991	05th Fl Passenger Elevator Lobby	11154
Simplex	2098-1234	5/1/1991	05th Fl Mechanical Room	11152
Simplex	2098-1234	1/1/1991	06th Fl Service Elevator Lobby	11161
Simplex	2098-1234	1/1/1991	06th Fl Passenger Elevator Lobby	11160
Simplex	2098-1234	1/1/1991	06th Fl Electrical Room	11159
Simplex	2098-1234	5/1/1991	06th Fl Mechanical Room	11158
Simplex	2098-1234	1/1/1991	07th Fl Electrical Room	11165
Simplex	2098-1234	1/1/1991	07th Fl Passenger Elevator Lobby	11166
Simplex	2098-1234	1/1/1991	07th Fl Service Elevator Lobby	11167
Simplex	2098-1234	5/1/1991	07th Fl Mechanical Room	11164
Simplex	2098-1234	1/1/1991	08th Fl Electrical Room	11171
Simplex	2098-1234	1/1/1991	08th Fl Service Elevator Lobby	11173
Simplex	2098-1234	1/1/1991	08th Fl Passenger Elevator Lobby	11172
Simplex	2098-1234	5/1/1991	08th Fl Mechanical Room	11170
Simplex	2098-1234	1/1/1991	09th Fl Service Elevator Lobby	11179
Simplex	2098-1234	1/1/1991	09th Fl Electrical Room	11177
Simplex	2098-1234	1/1/1991	09th Fl Passenger Elevator Lobby	11178
Simplex	2098-1234	5/1/1991	09th Fl Mechanical Room	11176

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

---

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Device Statistics

Report Date: 8/30/2005

Page 5 of 6

Manufacturer	Model #	Install Date	Device Location	Unit #
--------------	---------	--------------	-----------------	--------

## Sample Building

### *Smoke Detector*

Simplex	2098-1234	1/1/1991	10th Fl Service Elevator Lobby	11185
Simplex	2098-1234	1/1/1991	10th Fl Passenger Elevator Lobby	11184
Simplex	2098-1234	1/1/1991	10th Fl Electrical Room	11183
Simplex	2098-1234	5/1/1991	10th Fl Mechanical Room	11182
Simplex	2098-1234	1/1/1991	11th Fl Electrical Room	11189
Simplex	2098-1234	1/1/1991	11th Fl Passenger Elevator Lobby	11190
Simplex	2098-1234	1/1/1991	11th Fl Service Elevator Lobby	11191
Simplex	2098-1234	5/1/1991	11th Fl Mechanical Room	11188
Simplex	2098-1234	1/1/1991	12th Fl Passenger Elevator Lobby	11196
Simplex	2098-1234	1/1/1991	12th Fl Service Elevator Lobby	11197
Simplex	2098-1234	1/1/1991	12th Fl Electrical Room	11195
Simplex	2098-1234	5/1/1991	12th Fl Mechanical Room	11194
Simplex	2098-1234	1/1/1991	14th Fl Electrical Room	11201
Simplex	2098-1234	1/1/1991	14th Fl Passenger Elevator Lobby	11202
Simplex	2098-1234	1/1/1991	14th Fl Service Elevator Lobby	11203
Simplex	2098-1234	5/1/1991	14th Fl Mechanical Room	11200
Simplex	2098-1234	1/1/1991	15th Fl Electrical Room	11207
Simplex	2098-1234	1/1/1991	15th Fl Service Elevator Lobby	11209
Simplex	2098-1234	1/1/1991	15th Fl Passenger Elevator Lobby	11208
Simplex	2098-1234	5/1/1991	15th Fl Mechanical Room	11206
Simplex	2098-1234	1/1/1991	16th Fl Passenger Elevator Lobby	11214
Simplex	2098-1234	1/1/1991	16th Fl Service Elevator Lobby	11215
Simplex	2098-1234	1/1/1991	16th Fl Electrical Room	11213
Simplex	2098-1234	5/1/1991	16th Fl Mechanical Room	11212
Simplex	2098-1234	1/1/1991	17th Fl Electrical Room	11219
Simplex	2098-1234	1/1/1991	17th Fl Passenger Elevator Lobby	11220
Simplex	2098-1234	1/1/1991	17th Fl Service Elevator Lobby	11221
Simplex	2098-1234	5/1/1991	17th Fl Mechanical Room	11218
Simplex	2098-1234	1/1/1991	18th Fl Electrical Room	11225
Simplex	2098-1234	1/1/1991	18th Fl Passenger Elevator Lobby	11226
Simplex	2098-1234	1/1/1991	18th Fl Service Elevator Lobby	11227
Simplex	2098-1234	5/1/1991	18th Fl Mechanical Room	11224
Simplex	2098-1234	1/1/1991	PH Fl Elevator Room	11330

### *Tamper Switch*

Potter	TS1	5/1/1990	01st Fl Pump Room	11126
--------	-----	----------	-------------------	-------

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Device Statistics

Report Date: 8/30/2005

Page 6 of 6

---

Manufacturer	Model #	Install Date	Device Location	Unit #
--------------	---------	--------------	-----------------	--------

---

## Sample Building

### *Tamper Switch*

Potter	TS1	5/1/2001	01st Fl Pump Room	11128
Potter	TS1	5/1/2001	01st Fl Pump Room	11127
Potter	TS1	5/1/1991	02nd Fl East Stairwell	11291
Potter	TS1	5/1/1991	03rd Fl East Stairwell	11293
Potter	TS1	5/1/1991	04th Fl East Stairwell	11295
Potter	TS1	5/1/1991	05th Fl East Stairwell	11297
Potter	TS1	5/1/1991	06th Fl East Stairwell	11299
Potter	TS1	5/1/1991	07th Fl East Stairwell	11301
Potter	TS1	5/1/1991	08th Fl East Stairwell	11303
Potter	TS1	5/1/1991	09th Fl East Stairwell	11305
Potter	TS1	5/1/1991	10th Fl East Stairwell	11307
Potter	TS1	5/1/1991	11th Fl East Stairwell	11309
Potter	TS1	5/1/1991	12th Fl East Stairwell	11311
Potter	TS1	5/1/1991	14th Fl East Stairwell	11313
Potter	TS1	5/1/1991	15th Fl East Stairwell	11315
Potter	TS1	5/1/1991	16th Fl East Stairwell	11317
Potter	TS1	5/1/1991	17th Fl East Stairwell	11319
Potter	TS1	5/1/1991	18th Fl East Stairwell	11321
Potter	TS1	5/1/1991	PH Fl East Stairwell	11329

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

---

904 Williamsburg Court, Mableton, Georgia 30126





# e-Fire™ Inspection Discrepancies

Report Date: 8/30/2005

Page 1 of 2

Device Type	Unit #	Device Location	Discrepancy
-------------	--------	-----------------	-------------

## Sample Building

### *Disc. #01*

Smoke Detector	11125	01st Floor Service Elevator Lobby	Detector did not initiate Elevator Recall
----------------	-------	-----------------------------------	---

### *Disc. #02*

Tamper Switch	11128	01st Floor Pump Room	Device is not mounted securely
---------------	-------	----------------------	--------------------------------

### *Disc. #03*

Smoke Detector	11143	03rd Floor Service Elevator Lobby	Detector Failed
----------------	-------	-----------------------------------	-----------------

### *Disc. #04*

Battery	11244	01st Floor Control Panel	Battery is now or will be past the expiration date
---------	-------	--------------------------	--

### *Disc. #05*

Battery	11245	01st Floor Control Panel	Battery is now or will be past the expiration date
---------	-------	--------------------------	--

### *Disc. #06*

Pull Station	11168	07th Floor East Stairwell	Blocked by filing cabinet in tenant space
--------------	-------	---------------------------	---

### *Disc. #07*

Speaker/Strobe		03rd Floor Suite 350 - ABC Computers	Low Sound Level
----------------	--	--------------------------------------	-----------------

### *Disc. #08*

Speaker/Strobe		02nd Floor Suite 200 - Accounting Area	Low Sound Level
----------------	--	--	-----------------

### *Disc. #09*

Speaker/Strobe		07th Floor Suite 720	Low Sound Level
----------------	--	----------------------	-----------------

### *Disc. #10*

Speaker/Strobe		09th Floor Suite 975	Low Sound Level
----------------	--	----------------------	-----------------

### *Disc. #11*

Speaker/Strobe		11th Floor Suite 1110	Low Sound Level
----------------	--	-----------------------	-----------------

### *Disc. #12*

Speaker/Strobe		17th Floor Suite 1760	Low Sound Level
----------------	--	-----------------------	-----------------

### *Disc. #13*

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



# e-Fire™ Inspection Discrepancies

Report Date: 8/30/2005

Page 2 of 2

Device Type	Unit #	Device Location	Discrepancy
-------------	--------	-----------------	-------------

---

## Sample Building

### *Disc. #13*

Speaker/Strobe		02nd Floor Suite 200 - Sales Department	Low Sound Level
----------------	--	--	-----------------

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

---

904 Williamsburg Court, Mableton, Georgia 30126



# Report Resolutions Proposal

Fire Guardian, Inc. will provide labor, equipment, and materials for the resolution of Fire Alarm System Inspection Report Discrepancies selected below during normal business hours. Prices quoted are subject to a \$250 minimum in order to cover travel mileage and labor setup costs. Should the total of items to be resolved amount to less than \$250, repairs will be invoiced on a "Time and Materials" basis. Resolution items with a "Cost" of "T and M" will be handled by Fire Guardian on a Time and Materials basis upon customer acceptance of the item. ALL SERVICES PERFORMED WILL BE TESTED UPON COMPLETION TO VERIFY PROPER OPERATION. SHOULD FIRE GUARDIAN BE UNABLE TO TEST THESE ITEMS UPON COMPLETION, ADDITIONAL CHARGES WILL APPLY FOR RETURN TRIPS. Sales Taxes are not included in the prices quoted.



Report Date: 8/30/2005  
Page 1 of 2

## Resolution Items

Unit #	Device Type	Device Location	Resolution	Cost	Customer Approval	
<i>(Circle One)</i>						
<b>Sample Building</b>						
<i>Disc. #01</i>	11125	Smoke Detector	01st Floor Service Elevator Lobby	Replace	\$145.00	Yes No
<i>Disc. #02</i>	11128	Tamper Switch	01st Floor Pump Room	Repair	\$0.00	Yes No
<i>Disc. #03</i>	11143	Smoke Detector	03rd Floor Service Elevator Lobby	Replace	\$145.00	Yes No
<i>Disc. #04</i>	11244	Battery	01st Floor Control Panel	Replace	\$35.00	Yes No
<i>Disc. #05</i>	11245	Battery	01st Floor Control Panel	Replace	\$35.00	Yes No
<i>Disc. #06</i>	11168	Pull Station	07th Floor East Stairwell	Customer to have tenant relocate filing cabinet	\$0.00	Yes No
<i>Disc. #07</i>		Speaker/Strobe	03rd Floor Suite 350 - ABC Computers	Add 3-Speaker/Strobes in the space	\$870.00	Yes No
<i>Disc. #08</i>		Speaker/Strobe	02nd Floor Suite 200 - Accounting Area	Add 2-Speaker/Strobe Units	\$590.00	Yes No
<i>Disc. #09</i>		Speaker/Strobe	07th Floor Suite 720	Add Speaker/Strobe Unit	\$340.00	Yes No
<i>Disc. #10</i>		Speaker/Strobe	09th Floor Suite 975	Add Speaker/Strobe Unit	\$340.00	Yes No

[www.FireGuardian.com](http://www.FireGuardian.com)

Copyright 2005 Fire Guardian, Inc. Office:770-739-6021 Fax:770-234-6293

904 Williamsburg Court, Mableton, Georgia 30126



## Resolution Items

Unit #	Device Type	Device Location	Resolution	Cost	Customer Approval
--------	-------------	-----------------	------------	------	-------------------

*(Circle One)*

### Sample Building

Disc. #11	Speaker/Strobe	11th Floor Suite 1110	Add Speaker/Strobe Unit	\$340.00	Yes No
Disc. #12	Speaker/Strobe	17th Floor Suite 1760	Add Speaker/Strobe Unit	\$340.00	Yes No
Disc. #13	Speaker/Strobe	02nd Floor Suite 200 - Sales Department	Add Speaker/Strobe Unit	\$340.00	Yes No

#### CUSTOMER ACCEPTANCE OF PROPOSAL

*As authorized to sign on behalf of the company/property listed above, I hereby accept this proposal for Fire Alarm Inspection resolutions as outlined above and agree that the company/property is responsible for payment of the services and/or equipment listed.*

Accepted By: \_\_\_\_\_

Title \_\_\_\_\_

Date \_\_\_\_\_